

TOWN OF WESTPORT - BUILDING DEPT
SITE INSPECTION TICKET - PERMIT # 84843
233 HILLSPPOINT RD

Date: 11/30/18 Type: New Building		Use: Residential PR: DBG Map No: E04
Zoning Permit: 42345 Date: 11/26/2018 Compliance:		Rescheck: R-49/20/30
Inspection Date: _____ Time: _____		Contact Name: _____
Inspection Type: _____		Contact Phone: _____
Owner: 233 LLC		Contractor: PEN BLDG CO LLC NHC Contact: PETER NISENSEN Cellular Phone: 203-822-8206

Work Description: NEW 2-STORY SINGLE FAMILY DWELLING OVER UNFINISHED LOWER LEVEL, 4 BEDROOMS AND UNFINISHED ATTIC.

Notes:

SUB-PERMITS					
Sub-Type	Date	Contractor	Sub Work Description	Contact	Lic.
Alarm					
Electric					
Service	12/10/18	TSILFIDES ANDY	CRS #3211475 - INSTALL 100 AMP OVERHEAD TEMP	TSILFIDES	E1
Plumbing	08/15/19	SHANAHAN, KEVIN C.	PLUMBING FOR NEW HOUSE, GAS TO TWO FIREPL		P1
Masonry Fireplace	08/16/19	CUSTOM STONE WORK	BASEMENT AND FIRST FLOOR FIREPLACES.		ULC
HVAC	09/04/19	KIRIAZIDIS ANTONIOS	INSTALL TRANE 95% 40,000 BTU, TRANE 2 TON 16 S	KIRIAZIDIS	D1

INSPECTIONS				
Date	Type	Comments	By	P / F
12/18/18	Temp Service	ok	PSH	Pass
12/19/18	Notes	RELEASED TEMP SERVICE	MGO	N/A
01/25/19	Footing	ok	PSH	Pass
02/06/19	Notes	rec'd rev structural drawings	DBG	N/A
02/15/19	Jobsite Visit	wall steel--will get pe on steel	PSH	N/A
07/03/19	Sheathing	need app'd plans on site/pe sign-off on steel?	DBG	N/A
08/20/19	1st Flue	ok (ext f.p.)	PSH	Pass
08/22/19	Hearth	OK-FOR MAIN LEVEL	PSH	Pass
08/27/19	1st Flue	2nd floor	DBG	Pass
08/30/19	Hearth	3rd floor - needs add'l re-bars flue side of hearth	DBG	N/A
12/23/19	Notes	ZONING PERMIT REVOKED 12/20/19	SKW	N/A
12/23/19	Notes	need stop work--zoning revoked	PSH	N/A
03/13/20	Notes	stop work 12/23/19	PSH	N/A